

FINAL REPORT

Report Date: 13-JAN-2020 11:34 AM

Sample Number: 200561779

Subm # : 100184205 Type : -FEE- MISC OTHER Customer : CITY OF ADRIAN
Study : FEE SERVICE - (Loca) : -LOGIN Attn : n/a
MISCELLANEOUS ID : ADRIAN - LAKE Samp Addr: LAKE
Logged : 07-Jan-2020 11:02 am Samp City : ADRIAN, MI
By : GIGLIETTI Collected : 01/06/20 08:35
Categ. : FEE - MISC. Loca Desc : LAKE
FEE - MISC.

| PARAMETER | RESULT | UNITS | RL | METHOD | COMMENTS |
|---------------------------|----------|----------|-----|-----------|----------|
| METHYLISOBORNEOL | 4.4 | NG/L | 1.0 | STM 6040E | |
| GEOSMIN | 5.4 | NG/L | 1.0 | STM 6040E | |
| DATE OF ANALYSIS REQUIRED | 01/09/20 | MM/DD/YY | | | |

All parameters were analyzed in accordance with EPA approved methods EXCEPT where noted in 'COMMENTS' column or in the discussion below. This report is not valid without the cover sheet.


Please note that not all the analytes listed above are NELAP certified. For identification of specific analytes maintaining this certification please contact the Laboratory Manager.

Perfluorinated compounds performed by isotope dilution (PFC Isotope) are not certified and New York NELAP only provides certification for PFOA and PFOS by method 537. RWA does maintain certifications in other states for perfluorinated compounds encompassing the entire list found in EPA method 537 and 537.1.

RL - Reporting Limits

J - The reported result is an estimate. The value is less than the minimum calibration level but greater than the calculated method detection limit (MDL)

Approved by and Date :


1/14/20

FINAL REPORT

Report Date: 13-JAN-2020 11:34 AM

Sample Number: 200561780

Subm #: 100184205 Type : -FEE- MISC OTHER Customer : CITY OF ADRIAN
Study : FEE SERVICE - (Loca) : -LOGIN Attn : n/a
MISCELLANEOUS ID : ADRIAN - BLEND
Logged : 07-Jan-2020 11:02 am Samp Addr: BLEND
By : GIGLIETTI Samp City : ADRIAN, MI
Categ. : FEE - MISC. Collected : 01/06/20 08:15
FEE - MISC. Loca Desc : BLEND

| PARAMETER | RESULT | UNITS | RL | METHOD | COMMENTS |
|---------------------------|----------|----------|-----|-----------|----------|
| METHYLISOBORNEOL | 1.1 | NG/L | 1.0 | STM 6040E | |
| GEOSMIN | 1.1 | NG/L | 1.0 | STM 6040E | |
| DATE OF ANALYSIS REQUIRED | 01/09/20 | MM/DD/YY | | | |

All parameters were analyzed in accordance with EPA approved methods EXCEPT where noted in 'COMMENTS' column or in the discussion below. This report is not valid without the cover sheet.


Please note that not all the analytes listed above are NELAP certified. For identification of specific analytes maintaining this certification please contact the Laboratory Manager.

Perfluorinated compounds performed by isotope dilution (PFC Isotope) are not certified and New York NELAP only provides certification for PFOA and PFOS by method 537. RWA does maintain certifications in other states for perfluorinated compounds encompassing the entire list found in EPA method 537 and 537.1.

RL - Reporting Limits

J - The reported result is an estimate. The value is less than the minimum calibration level but greater than the calculated method detection limit (MDL)

Approved by and Date :


1/14/20

FINAL REPORT

Report Date: 13-JAN-2020 11:34 AM

Sample Number: 200561781

Subm # : 100184205 Type : -FEE- MISC OTHER Customer : CITY OF ADRIAN
Study : FEE SERVICE - (Loca) : -LOGIN Attn : n/a
MISCELLANEOUS ID : ADRIAN - TAP
Logged : 07-Jan-2020 11:02 am Samp Addr: TAP
By : GIGLIETTI Samp City : ADRIAN, MI
Categ. : FEE - MISC. Collected : 01/06/20 08:10
FEE - MISC. Loca Desc : TAP

| PARAMETER | RESULT | UNITS | RL | METHOD | COMMENTS |
|---------------------------|----------|----------|-----|-----------|----------|
| METHYLISOBORNEOL | 1.4 | NG/L | 1.0 | STM 6040E | |
| GEOSMIN | 1.1 | NG/L | 1.0 | STM 6040E | |
| DATE OF ANALYSIS REQUIRED | 01/09/20 | MM/DD/YY | | | |

All parameters were analyzed in accordance with EPA approved methods EXCEPT where noted in 'COMMENTS' column or in the discussion below. This report is not valid without the cover sheet.

Please note that not all the analytes listed above are NELAP certified. For identification of specific analytes maintaining this certification please contact the Laboratory Manager.

Perfluorinated compounds performed by isotope dilution (PFC Isotope) are not certified and New York NELAP only provides certification for PFOA and PFOS by method 537. RWA does maintain certifications in other states for perfluorinated compounds encompassing the entire list found in EPA method 537 and 537.1.

RL - Reporting Limits

J - The reported result is an estimate. The value is less than the minimum calibration level but greater than the calculated method detection limit (MDL)

Approved by and Date :


1/14/20

Regional Water Authority

90 Sargent Dr, New Haven, CT 06511

Phone: 203-401-2700

Fax: 203-401-6799

Chain of Custody Form

Company Name

CITY OF ADRIAN

Company Address

815 BENT OAK AVE.

ADRIAN, MI 49221

PO Number

Sample Type

Number of Bottles

MIB/Geosmin - 6040E 40mL Amber Glass
Vial w/Sodium Omatine

State Sample Collected:

CT ___ NY ___ Other(specify) ___

Evidence of Cooling (Circle): Y or N

Cooler Temp °C: 3.0

Container & Preservative Meet Criteria

(Circle): Yes/No

Remarks

RWA LIMS
Number

Date
Collected

Time
Collected

Facility ID

20056179

1/6/2020

8:35A

LAKE

2

2

780

1/6/2020

8:15A

BLEND

2

2

781

1/6/2020

8:10A

TAP

2

2

Relinquished By (Signature):

[Signature]

Relinquished by (Signature):

[Signature]

Lab Comments:

Date & Time: 1/6/20 9:30A

Date & Time:

Received By (Signature):

[Signature]

Received By (Signature):

[Signature]

Date & Time: 1-7-20 @ 1100

Date & Time: