

FINAL REPORT

Report Date: 24-JUL-2020 12:21 PM

Sample Number: 200583575

Subm # : 100193965 Type : -FEE- MISC OTHER Customer : ADRIAN WTP
Study : FEE SERVICE - (Loca) : -LOGIN Attn : n/a
 MISCELLANEOUS ID : ADRIAN - LAKE Samp Addr: LAKE
Logged : 21-Jul-2020 03:12 pm Samp City : ADRIAN MI
By : GIGLIETTI Collected : 07/20/20 09:15
Categ. : FEE - MISC. Loca Desc : LAKE
 FEE - MISC.

PARAMETER	RESULT	UNITS	RL	METHOD	COMMENTS
METHYLISOBORNEOL	14.9	NG/L	1.0	STM 6040E	
GEOSMIN	2.5	NG/L	1.0	STM 6040E	
DATE OF ANALYSIS REQUIRED	07/23/20	MM/DD/YY			

All parameters were analyzed in accordance with EPA approved methods EXCEPT where noted in 'COMMENTS' column or in the discussion below. This report is not valid without the cover sheet.

Please note that not all the analytes listed above are NELAP certified. For identification of specific analytes maintaining this certification please contact the Laboratory Manager.

Perfluorinated compounds performed by isotope dilution (PFC Isotope) are not certified and New York NELAP only provides certification for PFOA and PFOS by method 537. RWA does maintain certifications in other states for perfluorinated compounds encompassing the entire list found in EPA method 537 and 537.1.

RL - Reporting Limits

J - The reported result is an estimate. The value is less than the minimum calibration level but greater than the calculated method detection limit (MDL)

Approved by and Date : 
7/24/20

FINAL REPORT

Report Date: 24-JUL-2020 12:21 PM

Sample Number: 200583577

Subm # : 100193965 Type : -FEE- MISC OTHER Customer : ADRIAN WTP
Study : FEE SERVICE - (Loca) : -LOGIN Attn : n/a
 MISCELLANEOUS ID : ADRIAN - BLEND Samp Addr: BLEND
Logged : 21-Jul-2020 03:12 pm Samp City : ADRIAN MI
By : GIGLIETTI Collected : 07/20/20 09:00
Categ. : FEE - MISC. Loca Desc : BLEND
 FEE - MISC.

PARAMETER	RESULT	UNITS	RL	METHOD	COMMENTS
METHYLISOBORNEOL	2.4	NG/L	1.0	STM 6040E	
GEOSMIN	<1.0	NG/L	1.0	STM 6040E	
DATE OF ANALYSIS REQUIRED	07/23/20	MM/DD/YY			


All parameters were analyzed in accordance with EPA approved methods EXCEPT where noted in 'COMMENTS' column or in the discussion below. This report is not valid without the cover sheet.

Please note that not all the analytes listed above are NELAP certified. For identification of specific analytes maintaining this certification please contact the Laboratory Manager.
Perfluorinated compounds performed by isotope dilution (PFC Isotope) are not certified and New York NELAP only provides certification for PFOA and PFOS by method 537. RWA does maintain certifications in other states for perfluorinated compounds encompassing the entire list found in EPA method 537 and 537.1.

RL - Reporting Limits

J - The reported result is an estimate. The value is less than the minimum calibration level but greater than the calculated method detection limit (MDL)

Approved by and Date :


7/24/20

FINAL REPORT

Report Date: 24-JUL-2020 12:21 PM

Sample Number: 200583578

Subm # : 100193965
Study : FEE SERVICE -
MISCELLANEOUS
Logged : 21-Jul-2020 03:12 pm
By : GIGLIETTI
Categ. : FEE - MISC.
FEE - MISC.

Type : -FEE- MISC OTHER
(Loca) : -LOGIN
ID : ADRIAN - TAP

Customer : ADRIAN WTP
Attn : n/a
Samp Addr: TAP
Samp City : ADRIAN MI
Collected : 07/20/20 09:00
Loca Desc : TAP

PARAMETER	RESULT	UNITS	RL	METHOD	COMMENTS
METHYLISOBORNEOL	2.4	NG/L	1.0	STM 6040E	
GEOSMIN	<1.0	NG/L	1.0	STM 6040E	
DATE OF ANALYSIS REQUIRED	07/23/20	MM/DD/YY			

All parameters were analyzed in accordance with EPA approved methods EXCEPT where noted in 'COMMENTS' column or in the discussion below. This report is not valid without the cover sheet.


Please note that not all the analytes listed above are NELAP certified. For identification of specific analytes maintaining this certification please contact the Laboratory Manager.

Perfluorinated compounds performed by isotope dilution (PFC Isotope) are not certified and New York NELAP only provides certification for PFOA and PFOS by method 537. RWA does maintain certifications in other states for perfluorinated compounds encompassing the entire list found in EPA method 537 and 537.1.

RL - Reporting Limits

J - The reported result is an estimate. The value is less than the minimum calibration level but greater than the calculated method detection limit (MDL)

Approved by and Date :


7/24/20