

FINAL REPORT

Report Date: 10-AUG-2020 11:30 AM

Sample Number: 200585272

Subm # : 100194854 Type : -FEE- MISC OTHER Customer : CITY OF ADRIAN
Study : FEE SERVICE - (Loca) : -LOGIN Attn : n/a
 MISCELLANEOUS ID : ADRIAN - RAW LAKE Samp Addr: RAW LAKE
Logged : 05-Aug-2020 12:02 pm Samp City : ADRIAN MI
By : GIGLIETTI Collected : 08/03/20 12:00
Categ. : FEE - MISC. Loca Desc : RAW LAKE
 FEE - MISC.

PARAMETER	RESULT	UNITS	RL	METHOD	COMMENTS
METHYLISOBORNEOL	24.5	NG/L	1.0	STM 6040E	
GEOSMIN	5.6	NG/L	1.0	STM 6040E	
DATE OF ANALYSIS REQUIRED	08/07/20	MM/DD/YY			

All parameters were analyzed in accordance with EPA approved methods EXCEPT where noted in 'COMMENTS' column or in the discussion below. This report is not valid without the cover sheet.


Please note that not all the analytes listed above are NELAP certified. For identification of specific analytes maintaining this certification please contact the Laboratory Manager.

Perfluorinated compounds performed by isotope dilution (PFC Isotope) are not certified and New York NELAP only provides certification for PFOA and PFOS by method 537. RWA does maintain certifications in other states for perfluorinated compounds encompassing the entire list found in EPA method 537 and 537.1.

RL - Reporting Limits

J - The reported result is an estimate. The value is less than the minimum calibration level but greater than the calculated method detection limit (MDL)

Approved by and Date :


8/11/20

FINAL REPORT

Report Date: 10-AUG-2020 11:31 AM

Sample Number: 200585273

Subm # : 100194854 Type : -FEE- MISC OTHER Customer : CITY OF ADRIAN
Study : FEE SERVICE - (Loca) : -LOGIN Attn : n/a
 MISCELLANEOUS ID : ADRIAN - RAW BLEND Samp Addr: RAW BLEND
Logged : 05-Aug-2020 12:02 pm Samp City : ADRIAN MI
By : GIGLIETTI Collected : 08/03/20 12:30
Categ. : FEE - MISC. Loca Desc : RAW BLEND
 FEE - MISC.

PARAMETER	RESULT	UNITS	RL	METHOD	COMMENTS
METHYLISOBORNEOL	1.5	NG/L	1.0	STM 6040E	
GEOSMIN	<1.0	NG/L	1.0	STM 6040E	
DATE OF ANALYSIS REQUIRED	08/07/20	MM/DD/YY			


All parameters were analyzed in accordance with EPA approved methods EXCEPT where noted in 'COMMENTS' column or in the discussion below. This report is not valid without the cover sheet.

Please note that not all the analytes listed above are NELAP certified. For identification of specific analytes maintaining this certification please contact the Laboratory Manager.

Perfluorinated compounds performed by isotope dilution (PFC Isotope) are not certified and New York NELAP only provides certification for PFOA and PFOS by method 537. RWA does maintain certifications in other states for perfluorinated compounds encompassing the entire list found in EPA method 537 and 537.1.

RL - Reporting Limits

J - The reported result is an estimate. The value is less than the minimum calibration level but greater than the calculated method detection limit (MDL)

Approved by and Date : 
8/11/20

FINAL REPORT

Report Date: 10-AUG-2020 11:30 AM


Sample Number: 200585271

Subm # : 100194854 Type : -FEE- MISC OTHER Customer : CITY OF ADRIAN
Study : FEE SERVICE - (Loca) : -LOGIN Attn : n/a
 MISCELLANEOUS ID : ADRIAN - TAP Samp Addr: TAP
Logged : 05-Aug-2020 12:02 pm Samp City : ADRIAN MI
By : GIGLIETTI Collected : 08/03/20 12:30
Categ. : FEE - MISC. Loca Desc : TAP
 FEE - MISC.

PARAMETER	RESULT	UNITS	RL	METHOD	COMMENTS
METHYLISOBORNEOL	1.3	NG/L	1.0	STM 6040E	
GEOSMIN	<1.0	NG/L	1.0	STM 6040E	
DATE OF ANALYSIS REQUIRED	08/07/20	MM/DD/YY			

All parameters were analyzed in accordance with EPA approved methods EXCEPT where noted in 'COMMENTS' column or in the discussion below. This report is not valid without the cover sheet.

Please note that not all the analytes listed above are NELAP certified. For identification of specific analytes maintaining this certification please contact the Laboratory Manager.
Perfluorinated compounds performed by isotope dilution (PFC Isotope) are not certified and New York NELAP only provides certification for PFOA and PFOS by method 537. RWA does maintain certifications in other states for perfluorinated compounds encompassing the entire list found in EPA method 537 and 537.1.
RL - Reporting Limits
J - The reported result is an estimate. The value is less than the minimum calibration level but greater than the calculated method detection limit (MDL)

Approved by and Date : 
8/11/20