



NOTES:

1. TRENCHES REQUIRING SHORING AND BRACING, DIMENSIONS SHALL BE TAKEN FROM THE INSIDE FACE OF THE SHORING AND BRACING.
2. NO ROCKS OR BOULDERS 4" OR LARGER TO BE USED IN BACKFILL.
3. FOUNDATION STONE SHALL BE REQUIRED WHEN SOIL CONDITIONS ARE UNSUITABLE.
4. ALL BACKFILL MATERIAL SHALL BE SUITABLE NATIVE MATERIAL.
5. BACKFILL SHALL BE TAMPED IN 6" LIFTS.
6. ACHIEVE 95% COMPACTION IN BACKFILL IN NON-PAVED AREAS AND 100% COMPACTION IN PAVED AREAS.
7. SEE PAVEMENT REPAIR DETAIL FOR PIPE LAID IN AN EXISTING PAVED STREET.



TITLE:	WATERMAIN TRENCH	REV DATE:	7/29/15	DWG NO:	W.001
PO BOX 1436 900 S. BECKFORD DRIVE HENDERSON, NC 27536	CITY OF HENDERSON	252-430-5728 (fax) 252-431-0124 www.ci.henderson.nc.us	SCALE:	SHEET #:	1 OF 1
			NTS		