



**NOTES:**

1. ONLY MANUFACTURED VALVE BOX EXTENSIONS SHALL BE ALLOWED.
2. VALVE OPERATING NUT MUST BE EXTENDED SO THAT THE DEPTH IS NO GREATER THAN 5' FROM THE SURFACE USING A MANUFACTURER APPROVED EXTENSION KIT.
3. VALVE BOX SHOULD NOT CONTACT MAIN OR VALVE.
4. VALVE BOX COVER TO BE LABELED "WATER" OR "SEWER" AS APPROPRIATE.



|   |   |  |
|---|---|--|
| TITLE:<br><b>TYPICAL VALVE BOX INSTALLATION</b> | REV DATE:<br>7/30/15  | DWG NO:<br>W.006   |
|   | PO BOX 1436<br>900 S. BECKFORD DRIVE<br>HENDERSON, NC 27536 | 252-430-5728<br>(fax) 252-431-0124<br>www.ci.henderson.nc.us |
| CITY OF HENDERSON                               |   | SHEET #:<br>1 OF 1   |