




CITY of MOUNT HOLLY FIRE MARSHAL'S OFFICE




DEAD-END FIRE APPARATUS ACCESS ROAD TURNAROUND


The NC Fire Code requires that dead-end fire apparatus access roads in excess of 150 feet in length shall be provided with an approved area for turning around fire apparatus, and the required turning radius of a fire apparatus shall be determined by the City of Mount Holly Fire Marshal's Office.




**96' Diameter
Cul-De-Sac**




60' "Y"



**Minimum Clearance
Around a Fire Hydrant**



120' Hammerhead



**Acceptable Alternative to
120' Hammerhead**

• PRIDE • HONOR • INTEGRITY

433 Killian Ave • Mount Holly, North Carolina 28120 •

(704) 822-2927

Email: bob.nightingale@mtholly.us